



CITY OF
Yuma
 Utilities Department
 Laboratory
 289 N. Figueroa Ave.
 Yuma, AZ 85364
 (928) 373-4596 or
 (928) 373-4597

Total Coliform & *E. coli* Summary for COY Potable Water

Month	2024			2023			2022			2021			2020		
	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>
January	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
February	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
March	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
April	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
May	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
June	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
July	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
August	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
September	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
October	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
November	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
December	108	0	0	108	0	0	108	0	0	108	0	0	108	0	0
Totals	972	0	0	1296	0	0	1296	0	0	1296	0	0	1296	0	0
MCL = 5%	%	0.00		%	0.00		%	0.00		%	0.00		%	0.00	

Month	2019			2018			2017			2016			2015		
	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>
January	108	0	0	108	0	0	112	1	0	109	0	0	107	1	0
February	108	0	0	108	0	0	109	0	0	109	0	0	103	0	0
March	108	0	0	108	0	0	109	0	0	109	0	0	105	0	0
April	108	0	0	108	0	0	109	0	0	109	0	0	104	0	0
May	108	0	0	108	0	0	109	0	0	109	0	0	105	0	0
June	108	0	0	108	0	0	108	0	0	109	0	0	109	0	0
July	108	0	0	108	0	0	108	0	0	109	0	0	109	0	0
August	108	0	0	108	0	0	108	0	0	109	0	0	109	0	0
September	111	1	0	108	0	0	108	0	0	109	0	0	112	1	0
October	108	0	0	108	0	0	108	0	0	109	0	0	109	0	0
November	108	0	0	108	0	0	108	0	0	109	0	0	109	0	0
December	108	0	0	108	0	0	108	0	0	109	0	0	108	0	0
Totals	1299	1	0	1296	0	0	1304	1	0	1308	0	0	1289	2	0
MCL = 5%	%	0.08		%	0.00		%	0.08		%	0.00		%	0.16	

Month	2014			2013			2012			2011			2010		
	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>	# Compliance Samples Collected	# Positive for Total Coliform	# Positive for <i>E. coli</i>
January	106	1	0	104	0	0	103	0	0	103	0	0	103	0	0
February	103	0	0	107	1	0	103	0	0	103	0	0	104	0	0
March	106	1	0	104	0	0	104	0	0	103	0	0	104	0	0
April	103	0	0	103	0	0	102	0	0	102	0	0	102	0	0
May	102	0	0	107	1	0	104	0	0	103	0	0	103	0	0
June	104	0	0	104	0	0	103	0	0	104	0	0	103	0	0
July	103	0	0	108	1	0	103	0	0	102	0	0	102	0	0
August	103	0	0	104	0	0	103	0	0	103	0	0	103	0	0
September	103	0	0	105	0	0	103	0	0	103	0	0	113	3	0
October	102	0	0	104	0	0	104	0	0	106	1	0	102	0	0
November	103	0	0	104	0	0	104	0	0	103	0	0	109	2	0
December	102	0	0	107	1	0	105	0	0	103	0	0	102	0	0
Totals	1240	2	0	1261	4	0	1241	0	0	1238	1	0	1250	5	0
MCL = 5%	%	0.16		%	0.32		%	0.00		%	0.08		%	0.40	